



Water Advisory Board

May 10, 2016




Water Treatment Plant Overview

- Three water treatment plants
- North plant built in 1920's, 10MGD
- Middle plant expanded in 1950's, 20MGD
- South plant built in 1980's, 12MGD
- Filtration plant built in 1920's, 42MGD
- Conventional Water Treatment, 42MGD



Aerial View



Conventional Water Treatment

- Chemical (coagulant) addition
- Coagulation and Flocculation
- Sedimentation
- Filtration
- Disinfection



Coagulation

- Turbidity in water has a negative charge which prevents it from settling out
- Positive charged metallic coagulant is added, such as aluminum sulfate
- A rapid mix ensures quick and efficient mixing of the chemical coagulant
- Coagulant neutralizes the negative charges on particles so they can coagulate



Flocculation

- Coagulants have been added and have neutralized the negative charged particles
- The water is slowly mixed to allow particles to collide and grow in mass
- Flocculated water then flows to a clarifier for settling



Clarification

- Water enters at the center of the clarifier
- As water makes it's way to the outer weir, large floc particles fall out as a sludge
- Sludge is raked off the bottom and pumped to waste
- The clear supernatant flows over the weirs and is transferred to the filters



Clarifier Repair (May 2016)



Filtration Process

- 15 Gravity filters – media consists of three feet of anthracite coal and one foot of sand
- Must filter remaining particulate matter to below 0.3 ntu's (TCEQ requirement)
- Necessary for removal of Cryptosporidium and Giardia (chlorine resistant protozoans)
- Filtered water is transferred to the Clearwell for disinfection



Filtration Building



Filter Rebuild (4 May 2016)



Disinfection

- Water is then disinfected with a 2-5 mg/L mixture of chlorine gas and liquid ammonium sulfate (LAS)
- Monochloramine is created by the mix of chlorine gas and LAS
- Monochloramine is used to prevent the creation of trihalomethanes (THM's), known carcinogens
- THM's are monitored quarterly in our distribution system by TCEQ contractors



Disinfection Facility



Disinfection Facility (chlorination)



Distribution (High Service Pumps)



Comparison of Treatment Technologies

| | Conventional | Microfiltration | MF / Reverse Osmosis |
|-----------------------|-------------------|-----------------|----------------------|
| Minerals | 0 | 0 | 5 |
| Suspended Solids | 5 | 5 | 5 |
| Organics | 2 | 2 | 5 |
| Heavy Metals | 1 | 1 | 5 |
| Pesticides/Herbicides | 1 | 1 | 5 |
| Turbidity | 3 | 5 | 5 |
| THM's | 2 | 2 | 5 |
| Treatment Ability | | | |
| 0 = none | 3 = good | | |
| 1 = poor | 4 = above average | | |
| 2 = fair | 5 = excellent | | |





Evaluating New Water Sources

- Mineral content (< 500 TDS)
- Suspended solids (jar testing)
- Organic content (THM potential)
- Known pollutants (radium, nitrate, arsenic)
- Unknown pollutants (stormwater runoff)
- Corrosivity (lead control in distribution pipes)
- Meet current and future EPA standards
- TCEQ will require characterization
- Can we meet these with our existing plant?



Source Water Suspended Solids



Red Arroyo Source - Positives

- Total dissolved solids 50-300, very good
- Supplemental source to our portfolio
- Organics, metals, and pollutants would be trapped in the reservoir, thus improving the quality of the river downstream



Red Arroyo Source - Negatives

- Cannot be considered as a potable water source until a source water characterization study is conducted and approved by TCEQ
- Must sample the beginning, middle, and end of every rain runoff event for a minimum of one year
- Because of known pollutants in stormwater, TCEQ will treat this water the same as wastewater. Testing must include the same constituents required at the RO-Reuse pilot study (estimated at \$0.25 M)
- After TCEQ reviews the source water characterization, they will recommend treatment options which will then require a pilot study



Red Arroyo Treatment Concerns

- Current plant does not have the ability to remove organics or heavy metals
- Direct introduction of unknown pollutants into our drinking water system
- Coagulant and treatability studies have never been conducted
- Turbidity of 50-3000 ntu would overload existing gravity filters
- TCEQ requires us to meet 0.3 ntu in finished water
- Current staff believes we could not meet TCEQ turbidity requirements with this water



Red Arroyo Diversion Canal (1970's)





Water Advisory Board

May 10, 2016

