



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903	Lab Number: 97 Collected: 9:50:00 AM Received: 1/12/2015 Reported: 1/28/2015
Project Name: Water Quality Laboratory Contact: Tymn Combest Sample ID: Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	1/12/2015	CML	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	1.04	mg/L	1/12/2015	CML	0.015	Hach 10205
Bicarbonate (HCO3)	151	mg/L	1/12/2015	CML	4	SM 2320-B
Calcium (as Ca)	86	mg/L	1/12/2015	CML	4	SM 3500-Ca-B
Chloride (Cl)	208	mg/L	1/12/2015	CML	4	SM 4500-Cl-B
Conductivity	1323	µs	1/12/2015	CML	1	SM 2510-B
Fluoride (F)	.53	mg/L	1/12/2015	CML	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	1/12/2015	CML	0.01	Hach 8008
Magnesium (as Mg)	44	mg/L	1/12/2015	CML	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.48	mg/L	1/12/2015	CML	0.23	Hach 10206
Ortho-phosphate (PO4)	0.07	mg/L	1/12/2015	CML	0.06	Hach 8048
pH Value	7.6	units	1/12/2015	CML		SM 4500-H+
Potassium (K)	15.0	mg/L	1/12/2015	CML	5	Hach 8049
Sodium (Na)	114	mg/L	1/12/2015	CML	4	calc.
Sulfate (SO4)	233	mg/L	1/12/2015	CML	10	Hach 10227
Total Alkalinity (as CaCO3)	124	mg/L	1/12/2015	CML	4	SM 2320-B
Total Dissolved Solids (TDS)	856	mg/L	1/12/2015	CML	5	calc.
Total Hardness (as CaCO3)	396	mg/L	1/12/2015	CML	4	SM 2340-C
Total Hardness (in Grains)	23.3	gr/gal	1/12/2015	CML		SM 2340-C

cc: Lab File

Tymn Combest
Water Quality Superintendent