



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903	Lab Number: 100 Collected: 1:30:00 PM Received: 2/10/2015 Reported: 2/12/2015
Project Name: Water Production Plant Contact: Charles McGuire Sample ID: Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	.1	mg/L	2/10/2015	CGM	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	.72	mg/L	2/10/2015	CGM	0.015	Hach 10205
Bicarbonate (HCO3)	229	mg/L	2/10/2015	CGM	4	SM 2320-B
Calcium (as Ca)	83	mg/L	2/10/2015	CGM	4	SM 3500-Ca-B
Chloride (Cl)	268	mg/L	2/10/2015	CGM	4	SM 4500-Cl-B
Conductivity	1599	µs	2/10/2015	CGM	1	SM 2510-B
Fluoride (F)	.57	mg/L	2/10/2015	CGM	0.1	Hach 8029
Iron (Fe)	.01	mg/L	2/10/2015	CGM	0.01	Hach 8008
Magnesium (as Mg)	53	mg/L	2/10/2015	CGM	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	.33	mg/L	2/10/2015	CGM	0.23	Hach 10206
Ortho-phosphate (PO4)	.13	mg/L	2/10/2015	CGM	0.06	Hach 8048
pH Value	7.5	units	2/10/2015	CGM		SM 4500-H+
Potassium (K)	13.0	mg/L	2/10/2015	CGM	5	Hach 8049
Sodium (Na)	142	mg/L	2/10/2015	CGM	4	calc.
Sulfate (SO4)	173	mg/L	2/10/2015	CGM	10	Hach 10227
Total Alkalinity (as CaCO3)	188	mg/L	2/10/2015	CGM	4	SM 2320-B
Total Dissolved Solids (TDS)	964	mg/L	2/10/2015	CGM	5	calc.
Total Hardness (as CaCO3)	424	mg/L	2/10/2015	CGM	4	SM 2340-C
Total Hardness (in Grains)	25	gr/gal	2/10/2015	CGM		SM 2340-C

cc: Lab File

Tymn Combest
Water Quality Superintendent