

SUBMERSIBLE DUPLEX LIFT STATION - PART 4 OF 4

1 - 3'W X 6'H (MIN.)
STANDARD HINGED
PERSONAL ACCESS GATE

6' MIN. STANDARD CHAIN LINK SAFETY FENCE WITH 3 TOP STRANDS
BARBED WIRE ON 6" SPACING ABOVE TOP OF CHAIN LINK. FENCE
FENCE SHALL BE BUILT A MINIMUM PARALLEL DISTANCE OF 5'
FROM FROM ANY PORTION OF THE LIFT STATION STRUCTURE.

BASE
ACCESS ROAD
& PARKING AREA

7' MIN.
FROM ALL
STRUCTURES

20' MIN.

8' MAX.

2 - 5'W X 6'H (MIN.) STANDARD HINGED ACCESS GATES
LOCKING AT CENTER POST WITH 3 STRANDS BARBED
WIRE ON 6" SPACING ABOVE TOP OF CHAIN LINK.
ACCESS GATES SHALL BE LOCATED AS DETAILED WITH
RESPECT TO LIFT STATION AND VALVE VAULT.

CITY OF SAN ANGELO

SUBMERSIBLE DUPLEX LIFT STATION

PART 4 OF 4

JUNE 2016

W-SA-LS-4

