



**NOTES**

1. ALL CONNECTIONS TO COPPER TUBING SHALL BE FLARED FITTINGS.
2. ALL PVC FITTINGS SHALL BE SCHEDULE 80 WITH GLUED JOINTS.
3. ANY BUSHINGS REQUIRED SHALL BE BRASS WITH NEOPRENE GASKET.
4. ANGLE STOP SHALL BE LOCATED BETWEEN 2' AND 5' FROM BACK OF CURB.

**CITY OF SAN ANGELO**

1" WATER SERVICE LINE

JUNE 2016

W-SL-1