



City of San Angelo

# Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



## LABORATORY REPORT

<b>Report To:</b> City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903	<b>Lab Number:</b> 253 <b>Collected:</b> 11:00:00 AM <b>Received:</b> 8/15/2017 <b>Reported:</b> 8/21/2017
<b>Project Name:</b> Water Production Plant <b>Contact:</b> Charles McGuire <b>Sample ID:</b> Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.1	mg/L	8/15/2017	AEV	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	1.31	mg/L	8/15/2017	AEV	0.015	Hach 10205
Bicarbonate (HCO3)	151	mg/L	8/15/2017	AEV	4	SM 2320-B
Calcium (as Ca)	74	mg/L	8/15/2017	AEV	4	SM 3500-Ca-B
Chloride (Cl)	204	mg/L	8/15/2017	AEV	4	SM 4500-Cl-B
Conductivity	1379	µs	8/15/2017	AEV	1	SM 2510-B
Fluoride (F)	0.47	mg/L	8/15/2017	AEV	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	8/15/2017	AEV	0.01	Hach 8008
Magnesium (as Mg)	49	mg/L	8/15/2017	AEV	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.58	mg/L	8/15/2017	AEV	0.23	Hach 10206
Ortho-phosphate (PO4)	0.19	mg/L	8/15/2017	AEV	0.06	Hach 8048
pH Value	8.0	units	8/15/2017	AEV		SM 4500-H+
Potassium (K)	9.0	mg/L	8/15/2017	AEV	5	Hach 8049
Sodium (Na)	135	mg/L	8/15/2017	AEV	4	calc.
Sulfate (SO4)	264	mg/L	8/15/2017	AEV	10	Hach 10227
Total Alkalinity (as CaCO3)	124	mg/L	8/15/2017	AEV	4	SM 2320-B
Total Dissolved Solids (TDS)	841	mg/L	8/15/2017	AEV	5	calc.
Total Hardness (as CaCO3)	384	mg/L	8/15/2017	AEV	4	SM 2340-C
Total Hardness (in Grains)	22.6	gr/gal	8/15/2017	AEV		SM 2340-C

cc: Lab File

Elena Velez-Reyes  
Laboratory Manager