



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Quality Laboratory 1324 Metcalfe San Angelo, TX 76903	Lab Number: 296 Collected: 4/5/2018 Received: 4/5/2018 Reported: 4/5/2018
Project Name: Water Production Plant Contact: Charles McGuire Sample ID: Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	4/5/2018	TTS	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	1.16	mg/L	4/5/2018	TTS	0.015	Hach 10205
Bicarbonate (HCO3)	210	mg/L	4/5/2018	TTS	4	SM 2320-B
Calcium (as Ca)	109	mg/L	4/5/2018	TTS	4	SM 3500-Ca-B
Chloride (Cl)	220	mg/L	4/5/2018	TTS	4	SM 4500-Cl-B
Conductivity	1400	µs	4/5/2018	TTS	1	SM 2510-B
Fluoride (F)	0.68	mg/L	4/5/2018	TTS	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	4/5/2018	TTS	0.01	Hach 8008
Magnesium (as Mg)	44	mg/L	4/5/2018	TTS	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.41	mg/L	4/5/2018	TTS	0.23	Hach 10206
Ortho-phosphate (PO4)	0.13	mg/L	4/5/2018	TTS	0.06	Hach 8048
pH Value	8.0	units	4/5/2018	TTS		SM 4500-H+
Potassium (K)	9.0	mg/L	4/5/2018	TTS	5	Hach 8049
Sodium (Na)	122	mg/L	4/5/2018	TTS	4	calc.
Sulfate (SO4)	234	mg/L	4/5/2018	TTS	10	Hach 10227
Total Alkalinity (as CaCO3)	172	mg/L	4/5/2018	TTS	4	SM 2320-B
Total Dissolved Solids (TDS)	1190	mg/L	4/5/2018	TTS	5	calc.
Total Hardness (as CaCO3)	452	mg/L	4/5/2018	TTS	4	SM 2340-C
Total Hardness (in Grains)	26.6	gr/gal	4/5/2018	TTS		SM 2340-C

cc: Lab File

Elena Velez-Reyes
Laboratory Manager