



City of San Angelo

# Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



## LABORATORY REPORT

<b>Report To:</b> City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903	<b>Lab Number:</b> 362 <b>Collected:</b> 9:00:00 AM <b>Received:</b> 11/14/2018 <b>Reported:</b> 11/19/2018
<b>Project Name:</b> Water Production Plant <b>Contact:</b> Charles McGuire <b>Sample ID:</b> Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	11/14/2018	CML	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	.94	mg/L	11/14/2018	CML	0.015	Hach 10205
Bicarbonate (HCO3)	137	mg/L	11/14/2018	CML	4	SM 2320-B
Calcium (as Ca)	70	mg/L	11/14/2018	CML	4	SM 3500-Ca-B
Chloride (Cl)	176	mg/L	11/14/2018	CML	4	SM 4500-Cl-B
Conductivity	1081	µs	11/14/2018	CML	1	SM 2510-B
Fluoride (F)	.55	mg/L	11/14/2018	CML	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	11/14/2018	CML	0.01	Hach 8008
Magnesium (as Mg)	31	mg/L	11/14/2018	CML	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.38	mg/L	11/14/2018	CML	0.23	Hach 10206
Ortho-phosphate (PO4)	0.03	mg/L	11/14/2018	CML	0.06	Hach 8048
pH Value	8.0	units	11/14/2018	CML		SM 4500-H+
Potassium (K)	7.0	mg/L	11/14/2018	CML	5	Hach 8049
Sodium (Na)	119	mg/L	11/14/2018	CML	4	calc.
Sulfate (SO4)	200	mg/L	11/14/2018	CML	10	Hach 10227
Total Alkalinity (as CaCO3)	112	mg/L	11/14/2018	CML	4	SM 2320-B
Total Dissolved Solids (TDS)	681	mg/L	11/14/2018	CML	5	calc.
Total Hardness (as CaCO3)	304	mg/L	11/14/2018	CML	4	SM 2340-C
Total Hardness (in Grains)	17.9	gr/gal	11/14/2018	CML		SM 2340-C

cc: Lab File

Elena Velez-Reyes  
Laboratory Manager