



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903			Lab Number: 455 Collected: 10:30:00 AM Received: 2/10/2020 Reported: 2/11/2020			
Project Name: Water Production Plant Contact: Charles McGuire Sample ID: Tap Sample						
Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.1	mg/L	2/10/2020	TTS	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.87	mg/L	2/10/2020	TTS	0.015	Hach 10205
Bicarbonate (HCO3)	239	mg/L	2/10/2020	TTS	4	SM 2320-B
Calcium (as Ca)	115	mg/L	2/10/2020	TTS	4	SM 3500-Ca-B
Chloride (Cl)	208	mg/L	2/10/2020	TTS	4	SM 4500-Cl-B
Conductivity	1381	µs	2/10/2020	TTS	1	SM 2510-B
Fluoride (F)	0.44	mg/L	2/10/2020	TTS	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	2/10/2020	TTS	0.01	Hach 8008
Magnesium (as Mg)	31	mg/L	2/10/2020	TTS	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.79	mg/L	2/10/2020	TTS	0.23	Hach 10206
Ortho-phosphate (PO4)	0.03	mg/L	2/10/2020	TTS	0.06	Hach 8048
pH Value	8.2	units	2/10/2020	TTS		SM 4500-H+
Potassium (K)	8.0	mg/L	2/10/2020	TTS	5	Hach 8049
Sodium (Na)	133	mg/L	2/10/2020	TTS	4	calc.
Sulfate (SO4)	213	mg/L	2/10/2020	TTS	10	Hach 10227
Total Alkalinity (as CaCO3)	196	mg/L	2/10/2020	TTS	4	SM 2320-B
Total Dissolved Solids (TDS)	910	mg/L	2/10/2020	TTS	5	calc.
Total Hardness (as CaCO3)	416	mg/L	2/10/2020	TTS	4	SM 2340-C
Total Hardness (in Grains)	24.5	gr/gal	2/10/2020	TTS		SM 2340-C

cc: Lab File

Elena Velez-Reyes
Laboratory Manager