

72 West College Avenue, San Angelo, Texas 76903 (325) 657-4219 • sapurch@cosatx.us • www.cosatx.us

Addendum Two

Date: March 16, 2020

RFP: PI-01-20 / East Mezzanine A/V Renovation

Open: March 25, 2020 / 2:30 PM Local Time April 8, 2020 / 2:30 PM Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the RFP:

Important Announcement: The Due/Open Date has been moved to April 8, 2020 at 2:30 p.m.

Q&As

Q: Do you have a controller for the Lumens Cameras that you would like to use?

A: We do have a joystick, but we are open to whatever the approved vendor suggests.

Q: Would you like to have the projector to be hidden in the ceiling when not in use, is there room above the ceiling?

A: The projector will remain where it is and does not need to be hidden. The ceiling is plaster and there is not any access or room.

Q: Of the 15 wireless microphones, only 2 lavaliere and 1 handheld are mentions. What type of mic do the other 13 mics need to be?

A: Whatever the vendor thinks best works for the space and our needs.

Q: Who will be operating the system? Will there be a trained AV tech for any function needing to use the AV system in this room?

A: One of our 2 person office will be operating the system. Depending on what tech is chosen for the project, training may be needed. Currently we are proficient using Rushworks V-Desk and the Tricaster TC-1.

Q: Will there need to be facilities available for a in experienced operator to be able to use the system?

A: We have space for a control room next door to the East Mezzanine.

Q: What type of connection or video format/codec is needed to stream to the PEG channel?

A: 1080i MPEG-2.

Q: Will this need to be routed to existing equipment in order to stream to the PEG channel?

A: Yes, the connection from the East Mezzanine which is on the first floor will connect to the RUSHWORKS A-LIST which is located in the basement.

Q: What type of connectivity is available for the RUSHWORKS A-LIST channel server?

A: To connect with the Rushworks A-List it will need to be SDI.

For other questions or clarifications, please contact the Purchasing Division at SAPurch@cosatx.us. Questions must be submitted by end of day April 1, 2020.

Sincerely,

Nolan A. Sosa Purchasing Manager

PI-01-20 • ADDENDUM TWO