



Addendum Three

Date: April 9, 2020

RFB: FS-03-20 / Generator Services • [Bid Webpage](#)

Open: April 14, 2020 / 2:00 PM Local Time via Zoom

The following clarifications, changes, additions, and/or deletions are hereby made to the RFB:

I. Zoom Public Opening Details:

The City of San Angelo Purchasing Division invites you to a scheduled Bid Opening via Zoom meeting.

TOPIC: [BID OPENING] RFB: FS-03-20/GENERATOR SERVICES
TIME: APR 14, 2020 02:00 PM CENTRAL TIME (US AND CANADA)

Join Zoom Meeting via Computer:

<https://us02web.zoom.us/j/344079847?pwd=MmxWWEtGbGFMc2t4azd2NzBKSmkQT09>

Meeting ID: 344 079 847

Password: FS0320

One tap mobile:

+13462487799,,344079847# US (Houston)

+16699006833,,344079847# US (San Jose)

Dial by your location:

+1 346 248 7799 US (Houston)

+1 669 900 6833 US (San Jose)

+1 301 715 8592 US

+1 312 626 6799 US (Chicago)

+1 929 436 2866 US (New York)

+1 253 215 8782 US

Meeting ID: 344 079 847

Password: 406437

Find your local number: <https://us02web.zoom.us/j/344079847>

II. Questions + Answers:

Q: Would you mind emailing me a copy of the bid tabulation when this contract was awarded last time?

A: You will find the previous bid tabulation here:

<https://www.cosatx.us/Home/Components/RFP/RFP/1459/311?seldept=44>

Q: Can you provide a valid serial number for the generators at the following sites? (The engine information that was provided does not appear to be a valid serial number with John Deere. Your vendors will also need the serial # of the generator package to be able to research what air filters are needed). –

1. Lone Wolf Lift



2. South Concho LS

3. Shiloh LS

A: These three units are not generators, but engine driven lift pumps. We will be requesting service on the engine only for these units.

Q: Southland Water - The caterpillar SR-4B generator is rated at 350kW and it shipped straight from Caterpillar without being mated to an engine. Would you mind having someone obtain the model and serial # off the data tag for the engine? (I've seen these CAT generator ends paired with many different sizes of caterpillar engines, so the engine model/serial number will tell me which filters the engine will need.)

A: See spreadsheet below for any available updated information.

Q: Sulfur Draw LS - the correct Taylor serial # should be 5 digits long and all numerical.

A: See spreadsheet below for any available updated information.

Q: I am working on quoting the open bid for generator maintenance and ran into an issue. On the serial number list, every parts company is unable to find the exact parts based on the generator serial number except for CAT. Do you have a list with the engine serial numbers instead of genset numbers? Also, the kW numbers do not match up with the corresponding generator. For example the Kohler 80RE0ZJB and 20RE0ZJB should be two different kW amounts. Can you please verify the kW amounts?

A: See spreadsheet below for any available updated information.

Q: How long will the load bank testing be when performing annual maintenance (Section 3.11)? 1, 2, 4 hours?

A: The City requests the vendor to determine what an appropriate amount of time for loan bank testing is and bid accordingly.

Q: There are some generators on the list with N/A under kW, I'm assuming those are fire pumps?

A: See question above.

Q: I saw the 2nd amendment on the generator bid packet. I only see part of the prices for last year's contract. Do you happen to have the prices for the maintenance services?

A: The City had a different bid format last year where the vendor was selected based off the general labor rates, then provided quotes for each unit upon request. Further, the information requested is either not readily available or requires a PIR. We hope you can still complete the solicitation based on the other information that has been provided. Public Information Requests may be submitted at www.cosatx.us/pir.

III. Generators Engine Information

<u>Unit Number</u>	<u>Location</u>	<u>Unit Make</u>	<u>Genset Model</u>	<u>Generator Serial #</u>	<u>Engine Model</u>	<u>Engine Serial #</u>	<u>KW</u>
11479	Coliseum	CAT			3306	9NR05121	100
11547	Southland Water	CAT	SR-4B	4WN00541			1000
11991	Terminal	CAT	3406	31DZ06531			400
11992	Hanger	Onan	DGEA-3384724	A000041954			125
18670	Lone Wolf Lift	John Deere	NA	NA	2360F 4.5L	PE4045D192105	NA
18671	South Concho	John Deere	NA	NA	2630F 4.5L	PE4045D262941	NA
18677	Shiloh	John Deere	NA	NA	2660F 6.8L	PE6068D237927	NA
22098	Abilene Tank	CAT	3456	G6B01819			500
22127	Nasworthy Dam	KOHLER	80RE0ZJB	2023619			80



**CITY OF SAN ANGELO
PURCHASING DIVISION**

72 West College Avenue, San Angelo, Texas 76903
(325) 657-4219 • sapurch@cosatx.us • www.cosatx.us

22128	Twin Butte	KOHLER	20RE0ZJB	4WN00541			20
22213	Station 8	Onan	DGDB-4960197	F010245470		46112120	100
22478	City Hall	MTU	DS00150	338215-1-1-1011			150
22479	EOC	Kohler	200ROZD	385876			200
22538	Water Reclamation	Onan	DQKAB-7042855	H110235818	QSK60-G6	33187D12	2000
22539	Water Production	Onan	DQKAB	H110242496			1000
22540	Water Production	Onan	DFEK	H110214295			500
-	Sulfurdraw LS	Taylor	224E3P1	Tp33054	NL70981	B503199C	55
-	St. Ann IT Tower	Kohler	25REZG	SGM32FZZV			25
-	Southland IT Tower	Kohler	25REZG	SGM32FZZW			25
23038	Dispatch	Kohler	100RE0ZJF	3346GMGJ0010			100
-	Water Plant	MTU	DS00100	373029-1-1-0414			100
-	Northside IT Tower	Kohler	50REZG	2317301			50
23022	Central Fire Station	Kohler	80RE0ZJF	33JVGGMGN0018		PE4045N024243	83

Note: Excel File available for download on Bid Webpage <https://www.cosatx.us/Home/Components/RFP/RFP/1545/311>

For other questions or clarifications, please contact the Purchasing Division at SAPurch@cosatx.us. The deadline to submit questions has passed (7 days before the Due/Open date).

Sincerely,

Nolan A. Sosa
Purchasing Manager