



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

<p>Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903</p>	<p>Lab Number: 461 Collected: 8:30:00 AM Received: 4/6/2020 Reported: 4/9/2020</p>
<p>Project Name: Water Production Plant Contact: Charles McGuire Sample ID: Tap Sample</p>	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	4/6/2020	CML	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.99	mg/L	4/6/2020	CML	0.015	Hach 10205
Bicarbonate (HCO3)	220	mg/L	4/6/2020	CML	4	SM 2320-B
Calcium (as Ca)	110	mg/L	4/6/2020	CML	4	SM 3500-Ca-B
Chloride (Cl)	196	mg/L	4/6/2020	CML	4	SM 4500-Cl-B
Conductivity	1391	µs	4/6/2020	CML	1	SM 2510-B
Fluoride (F)	0.63	mg/L	4/6/2020	CML	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	4/6/2020	CML	0.01	Hach 8008
Magnesium (as Mg)	42	mg/L	4/6/2020	CML	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.77	mg/L	4/6/2020	CML	0.23	Hach 10206
Ortho-phosphate (PO4)	0.09	mg/L	4/6/2020	CML	0.06	Hach 8048
pH Value	7.9	units	4/6/2020	CML		SM 4500-H+
Potassium (K)	6.0	mg/L	4/6/2020	CML	5	Hach 8049
Sodium (Na)	112	mg/L	4/6/2020	CML	4	calc.
Sulfate (SO4)	229	mg/L	4/6/2020	CML	10	Hach 10227
Total Alkalinity (as CaCO3)	180	mg/L	4/6/2020	CML	4	SM 2320-B
Total Dissolved Solids (TDS)	917	mg/L	4/6/2020	CML	5	calc.
Total Hardness (as CaCO3)	448	mg/L	4/6/2020	CML	4	SM 2340-C
Total Hardness (in Grains)	26.4	gr/gal	4/6/2020	CML		SM 2340-C

cc: Lab File

Elena Velez-Reyes
Laboratory Manager