



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

<p>Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903</p> <p>Project Name: Water Production Plant Contact: Charles McGuire Sample ID: Tap Sample</p>	<p>Lab Number: 480 Collected: 8:30:00 AM Received: 10/6/2020 Reported: 10/8/2020</p>
---	---

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	.10	mg/L	10/6/2020	CML	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	1.07	mg/L	10/6/2020	CML	0.015	Hach 10205
Bicarbonate (HCO3)	215	mg/L	10/6/2020	CML	4	SM 2320-B
Calcium (as Ca)	64	mg/L	10/6/2020	CML	4	SM 3500-Ca-B
Chloride (Cl)	280	mg/L	10/6/2020	CML	4	SM 4500-Cl-B
Conductivity	1540	µs	10/6/2020	CML	1	SM 2510-B
Fluoride (F)	0.56	mg/L	10/6/2020	CML	0.1	Hach 8029
Iron (Fe)	0.02	mg/L	10/6/2020	CML	0.01	Hach 8008
Magnesium (as Mg)	15	mg/L	10/6/2020	CML	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.26	mg/L	10/6/2020	CML	0.23	Hach 10206
Ortho-phosphate (PO4)	0.03	mg/L	10/6/2020	CML	0.06	Hach 8048
pH Value	7.8	units	10/6/2020	CML		SM 4500-H+
Potassium (K)	9.0	mg/L	10/6/2020	CML	5	Hach 8049
Sodium (Na)	288	mg/L	10/6/2020	CML	4	calc.
Sulfate (SO4)	273	mg/L	10/6/2020	CML	10	Hach 10227
Total Alkalinity (as CaCO3)	176	mg/L	10/6/2020	CML	4	SM 2320-B
Total Dissolved Solids (TDS)	1015	mg/L	10/6/2020	CML	5	calc.
Total Hardness (as CaCO3)	220	mg/L	10/6/2020	CML	4	SM 2340-C
Total Hardness (in Grains)	13.0	gr/gal	10/6/2020	CML		SM 2340-C

cc: Lab File

Elena Velez-Reyes
 Laboratory Manager