

	Date Collected	2/8/2021	2/8/2021	2/8/2021	2/8/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021
	Time Collected	10:25	12:18	12:30	13:32	8:37	9:48	9:58	10:11	10:36	10:52	11:01	11:18	11:49	11:38
Drinking Water	Lab ID	2103753001	2103753002	2103753003	2103753004	2103796001	2103796002	2103796003	2103796004	2103796005	2103796006	2103796007	2103796008	2103796009	2103796010
Regulated MCL*	Sample ID	2809	3085	2621	2014	1871	2133	2019	1073	1441	1925	1924	1819	751	3713
(ppb = ug/L)															
	Tetrahydrofuran (ppb)	7.33	4.76	9.07	7.22	ND	ND	ND	ND						
5	Benzene (ppb)	17.9	17.3	177	35.1	ND	ND	ND	ND						
	Acetone (ppb)	ND	ND	7.96	ND	ND	ND	ND							
	Acrylonitrile (ppb)	ND	ND	4.25	1.33	ND	ND	ND	ND						
	2-Butonone (ppb)	ND	ND	2.51	1.14	ND	ND	ND	ND						
1000	Toluene (ppb)	0.58	ND	4.54	0.92	ND	ND	ND	ND						
100	Styrene (ppb)	ND	ND	3.13	ND	ND	ND	ND							
	Naphthalene (ppb)	ND	ND	141	5.93	ND	ND	ND	ND						
5	1,2- Dichloroethane (ppb)	ND	ND	3.6	0.87	ND	ND	ND	ND						
	Vinyl chloride (ppb)	ND	ND	ND	0.53	ND	ND	ND	ND						
	Trihalomethanes														
	Chloroform (ppb)	1.92	1.91	1.48	1.8	2.04	2.18	2.02	1.95	1.81	1.99	2.05	2.13	2.06	2.01
	Bromodichloromethane (ppb)	5.71	5.49	4.04	5.43	5.69	6.15	5.55	5.33	5.24	5.37	5.67	5.67	5.42	5.56
	Dibromochloromethane (ppb)	10.4	10.2	7.53	9.9	9.21	11.7	8.78	8.13	8.02	7.93	8.63	8.84	8.94	8.58
	Bromoform (ppb)	15.9	15.4	11	14.6	11	14.6	9.96	8.42	8.24	8.14	8.73	9.26	8.97	9
80	Total Trihalomethanes	33.93	33	24.05	31.73	27.94	34.63	26.31	23.83	23.31	23.43	25.08	25.9	25.39	25.15

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 2/24/2021

Original spreadsheet left off the "2" at the beginning of the Sample ID for the samples collected 2/8/2021 through 2/9/2021. The Lab ID starts with the current year, 21, but those rows started with a 1, lacking the "2".

	Date Collected	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/9/2021	2/10/2021
	Time Collected	11:02	10:50	10:45	9:50	9:33	9:27	9:15	9:05	8:45	9:00	11:25	10:03	7:40
Drinking Water	Lab ID	2103796011	2103796012	2103796013	2103796014	2103796015	2103796016	2103796017	2103796018	2103796019	2103796020	2103796021	2103796022	2103994001
Regulated MCL*	Sample ID	1226	2866	2955	3221	683	687	3446	684	761	760	College Hill	Tractor Trail	1367
(ppb = ug/L)														
	Tetrahydrofuran (ppb)	ND	ND	ND	ND	ND								
5	Benzene (ppb)	ND	ND	1.78	2.91	ND	ND	ND	ND	4.91	ND	ND	ND	ND
	Acetone (ppb)	ND	ND	ND	ND	ND								
	Acrylonitrile (ppb)	ND	ND	ND	ND	ND								
	2-Butonone (ppb)	ND	ND	ND	ND	ND								
1000	Toluene (ppb)	ND	ND	ND	ND	ND								
100	Styrene (ppb)	ND	ND	ND	ND	ND								
	Naphthalene (ppb)	ND	ND	ND	ND	ND								
5	1,2- Dichloroethane (ppb)	ND	ND	ND	ND	ND								
	Vinyl chloride (ppb)	ND	ND	ND	ND	ND								
	Trihalomethanes													
	Chloroform (ppb)	2.11	2.13	1.97	2.04	2.02	2.00	2.02	1.98	1.19	1.91	1.91	1.81	2.02
	Bromodichloromethane (ppb)	5.77	6.15	5.44	5.9	5.96	6.06	6.15	5.99	2.86	5.79	5.91	5.16	6.24
	Dibromochloromethane (ppb)	8.86	9.57	8.87	10.1	10.2	10.5	10.3	10.6	5.05	10.6	11.4	9.83	10.9
	Bromoform (ppb)	9.67	10.5	10.5	12.1	12	12.2	12.4	12	7.64	15.1	17.5	15.1	15.4
80	Total Trihalomethanes	26.41	28.35	26.78	30.14	30.18	30.76	30.87	30.57	16.74	33.4	36.72	31.9	34.56

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 2/24/2021

Original spreadsheet left off the "2" at the beginning of t

	Date Collected	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/10/2021	2/11/2021	2/11/2021
	Time Collected	8:02	8:13	8:22	8:35	8:22	8:12	8:07	7:38	7:43	7:54	8:40	11:16	11:27
Drinking Water	Lab ID	2103994002	2103994003	2103994004	2103994005	2103994006	2103994007	2103994008	2103994009	2103994010	2103994011	2103994012	2104173001	2104173002
Regulated MCL*	Sample ID	761	3221	81	956	802	705	502	401	1727	1948	2621	684	142-21S
(ppb = ug/L)														
	Tetrahydrofuran (ppb)	ND												
5	Benzene (ppb)	ND	14.4	1.63	1.74	ND								
	Acetone (ppb)	ND												
	Acrylonitrile (ppb)	ND												
	2-Butonone (ppb)	ND												
1000	Toluene (ppb)	ND												
100	Styrene (ppb)	ND												
	Naphthalene (ppb)	ND												
5	1,2- Dichloroethane (ppb)	ND												
	Vinyl chloride (ppb)	ND												
	Trihalomethanes													
	Chloroform (ppb)	2.07	1.6	1.9	1.93	2.01	1.99	2.2	2.18	2.01	1.85	1.95	2.42	2.47
	Bromodichloromethane (ppb)	6.31	4.76	5.83	5.67	6.17	5.89	6.38	6.38	6.06	5.36	5.88	7.24	7.35
	Dibromochloromethane (ppb)	11.4	9.02	11.1	9.96	11.3	10.4	10.2	10	10.6	9.07	10.4	12.6	13
	Bromoform (ppb)	15.8	13.4	16.5	19.4	16.6	14.9	13.1	12.1	15.3	13.1	15.2	15.7	16.3
80	Total Trihalomethanes	35.58	28.78	35.33	36.96	36.08	33.18	31.88	30.66	33.97	29.38	33.43	37.96	39.12

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 2/24/2021

Original spreadsheet left off the "2" at the beginning of t

	Date Collected	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021	2/11/2021
	Time Collected	11:34	11:54	12:05	12:09	12:18	13:38	13:50	11:09	11:39	11:52	12:38	23:40
Drinking Water	Lab ID	2104173003	2104173004	2104173005	2104173006	2104173007	2104173008	2104173009	2104173010	2104173011	2104173012	2104173013	2104173014
Regulated MCL*	Sample ID	682	2907	760	761	3221	502	3706	2097-25S	129	1288	56P	1421
(ppb = ug/L)													
	Tetrahydrofuran (ppb)	ND											
5	Benzene (ppb)	ND	ND	ND	ND	6.3	ND	30.6	ND	ND	ND	ND	ND
	Acetone (ppb)	ND											
	Acrylonitrile (ppb)	ND											
	2-Butonone (ppb)	ND											
1000	Toluene (ppb)	ND											
100	Styrene (ppb)	ND											
	Naphthalene (ppb)	ND											
5	1,2- Dichloroethane (ppb)	ND											
	Vinyl chloride (ppb)	ND											
	Trihalomethanes												
	Chloroform (ppb)	2.54	2.78	2.56	2.53	2.27	2.3	1.23	2.21	2.65	2.43	2.37	2.66
	Bromodichloromethane (ppb)	7.38	8.06	7.77	7.47	6.73	6.84	2.75	6.92	7.88	7.17	6.72	7.52
	Dibromochloromethane (ppb)	12.9	13	13.5	13	12.2	12.1	5.04	13.3	12.8	11.9	10.2	12
	Bromoform (ppb)	16	15	16.7	16.6	17.2	15.5	7.23	18	14.5	14.3	11.5	13.7
80	Total Trihalomethanes	38.82	38.84	40.53	39.6	38.4	36.74	16.25	40.43	37.83	35.8	30.79	35.88

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 2/24/2021

Original spreadsheet left off the "2" at the beginning of t