

| | Date Collected | 2/8/2021 | 2/8/2021 | 2/8/2021 | 2/8/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 |
|----------------|---------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 10:25 | 12:18 | 12:30 | 13:32 | 8:37 | 9:48 | 9:58 | 10:11 | 10:36 | 10:52 | 11:01 | 11:18 |
| Drinking Water | Lab ID | 2103753001 | 2103753002 | 2103753003 | 2103753004 | 2103796001 | 2103796002 | 2103796003 | 2103796004 | 2103796005 | 2103796006 | 2103796007 | 2103796008 |
| Regulated MCL* | Sample ID | 2809 | 3085 | 2621 | 2014 | 1871 | 2133 | 2019 | 1073 | 1441 | 1925 | 1924 | 1819 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | 7.33 | 4.76 | 9.07 | 7.22 | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | 17.9 | 17.3 | 177 | 35.1 | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | 7.96 | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | 4.25 | 1.33 | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | 2.51 | 1.14 | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | 0.58 | ND | 4.54 | 0.92 | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | 3.13 | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | 141 | 5.93 | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | 3.6 | 0.87 | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | 0.62 | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | 0.53 | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.92 | 1.91 | 1.48 | 1.8 | 2.04 | 2.18 | 2.02 | 1.95 | 1.81 | 1.99 | 2.05 | 2.13 |
| | Bromodichloromethane (ppb) | 5.71 | 5.49 | 4.04 | 5.43 | 5.69 | 6.15 | 5.55 | 5.33 | 5.24 | 5.37 | 5.67 | 5.67 |
| | Dibromochloromethane (ppb) | 10.4 | 10.2 | 7.53 | 9.9 | 9.21 | 11.7 | 8.78 | 8.13 | 8.02 | 7.93 | 8.63 | 8.84 |
| | Bromoform (ppb) | 15.9 | 15.4 | 11 | 14.6 | 11 | 14.6 | 9.96 | 8.42 | 8.24 | 8.14 | 8.73 | 9.26 |
| 80 | Total Regulated Trihalomethanes | 33.93 | 33 | 24.05 | 31.73 | 27.94 | 34.63 | 26.31 | 23.83 | 23.31 | 23.43 | 25.08 | 25.9 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021

--- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 | 2/9/2021 |
|----------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|
| | Time Collected | 11:49 | 11:38 | 11:02 | 10:50 | 10:45 | 9:50 | 9:33 | 9:27 | 9:15 | 9:05 | 8:45 | 9:00 |
| Drinking Water | Lab ID | 2103796009 | 2103796010 | 2103796011 | 2103796012 | 2103796013 | 2103796014 | 2103796015 | 2103796016 | 2103796017 | 2103796018 | 2103796019 | 2103796020 |
| Regulated MCL* | Sample ID | 751 | 3713 | 1226 | 2866 | 2955 | 3221 | 683 | 687 | 3446 | 684 | 761 | 760 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | 1.78 | 2.91 | ND | ND | ND | ND | 4.91 | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 2.06 | 2.01 | 2.11 | 2.13 | 1.97 | 2.04 | 2.02 | 2.00 | 2.02 | 1.98 | 1.19 | 1.91 |
| | Bromodichloromethane (ppb) | 5.42 | 5.56 | 5.77 | 6.15 | 5.44 | 5.9 | 5.96 | 6.06 | 6.15 | 5.99 | 2.86 | 5.79 |
| | Dibromochloromethane (ppb) | 8.94 | 8.58 | 8.86 | 9.57 | 8.87 | 10.1 | 10.2 | 10.5 | 10.3 | 10.6 | 5.05 | 10.6 |
| | Bromoform (ppb) | 8.97 | 9 | 9.67 | 10.5 | 10.5 | 12.1 | 12 | 12.2 | 12.4 | 12 | 7.64 | 15.1 |
| 80 | Total Regulated Trihalomethanes | 25.39 | 25.15 | 26.41 | 28.35 | 26.78 | 30.14 | 30.18 | 30.76 | 30.87 | 30.57 | 16.74 | 33.4 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/9/2021 | 2/9/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 | 2/10/2021 |
|-----------------------------|--|--------------|---------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 11:25 | 10:03 | 7:40 | 8:02 | 8:13 | 8:22 | 8:35 | 8:22 | 8:12 | 8:07 | 7:38 | 7:43 |
| Drinking Water | Lab ID | 2103796021 | 2103796022 | 2103994001 | 2103994002 | 2103994003 | 2103994004 | 2103994005 | 2103994006 | 2103994007 | 2103994008 | 2103994009 | 2103994010 |
| Regulated MCL* (ppb = ug/L) | Sample ID | College Hill | Tractor Trail | 1367 | 761 | 3221 | 81 | 956 | 802 | 705 | 502 | 401 | 1727 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | 14.4 | 1.63 | 1.74 | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.91 | 1.81 | 2.02 | 2.07 | 1.6 | 1.9 | 1.93 | 2.01 | 1.99 | 2.2 | 2.18 | 2.01 |
| | Bromodichloromethane (ppb) | 5.91 | 5.16 | 6.24 | 6.31 | 4.76 | 5.83 | 5.67 | 6.17 | 5.89 | 6.38 | 6.38 | 6.06 |
| | Dibromochloromethane (ppb) | 11.4 | 9.83 | 10.9 | 11.4 | 9.02 | 11.1 | 9.96 | 11.3 | 10.4 | 10.2 | 10 | 10.6 |
| | Bromoform (ppb) | 17.5 | 15.1 | 15.4 | 15.8 | 13.4 | 16.5 | 19.4 | 16.6 | 14.9 | 13.1 | 12.1 | 15.3 |
| 80 | Total Regulated Trihalomethanes | 36.72 | 31.9 | 34.56 | 35.58 | 28.78 | 35.33 | 36.96 | 36.08 | 33.18 | 31.88 | 30.66 | 33.97 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/10/2021 | 2/10/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/11/2021 |
|-----------------------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|-------------|--------------|--------------|--------------|
| | Time Collected | 7:54 | 8:40 | 11:16 | 11:27 | 11:34 | 11:54 | 12:05 | 12:09 | 12:18 | 13:38 | 13:50 | 11:09 |
| Drinking Water | Lab ID | 2103994011 | 2103994012 | 2104173001 | 2104173002 | 2104173003 | 2104173004 | 2104173005 | 2104173006 | 2104173007 | 2104173008 | 2104173009 | 2104173010 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 1948 | 2621 | 684 | 142-215 | 682 | 2907 | 760 | 761 | 3221 | 502 | 3706 | 2097-255 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | 6.3 | ND | 30.6 | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.85 | 1.95 | 2.42 | 2.47 | 2.54 | 2.78 | 2.56 | 2.53 | 2.27 | 2.3 | 1.23 | 2.21 |
| | Bromodichloromethane (ppb) | 5.36 | 5.88 | 7.24 | 7.35 | 7.38 | 8.06 | 7.77 | 7.47 | 6.73 | 6.84 | 2.75 | 6.92 |
| | Dibromochloromethane (ppb) | 9.07 | 10.4 | 12.6 | 13 | 12.9 | 13 | 13.5 | 13 | 12.2 | 12.1 | 5.04 | 13.3 |
| | Bromoform (ppb) | 13.1 | 15.2 | 15.7 | 16.3 | 16 | 15 | 16.7 | 16.6 | 17.2 | 15.5 | 7.23 | 18 |
| 80 | Total Regulated Trihalomethanes | 29.38 | 33.43 | 37.96 | 39.12 | 38.82 | 38.84 | 40.53 | 39.6 | 38.4 | 36.74 | 16.25 | 40.43 |

* MCL = Maximum Contaminant Level
 ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/11/2021 | 2/11/2021 | 2/11/2021 | 2/10/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 |
|-----------------------------|---------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 11:39 | 11:52 | 12:38 | 23:40 | 8:05 | 8:25 | 8:45 | 9:00 | 9:25 | 9:47 | 10:10 | 10:36 |
| Drinking Water | Lab ID | 2104173011 | 2104173012 | 2104173013 | 2104173014 | 2104206001 | 2104206002 | 2104206003 | 2104206004 | 2104206005 | 2104206006 | 2104206007 | 2104206008 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 129 | 1288 | 56P | 1421 | 1925 | 1924 | 1819 | 706 | 3720 | 956 | 3625 | 1025 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | 0.53 |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 2.65 | 2.43 | 2.37 | 2.66 | 2.85 | 2.34 | 2.48 | 2.3 | 2.35 | 2.75 | 2.4 | 2.81 |
| | Bromodichloromethane (ppb) | 7.88 | 7.17 | 6.72 | 7.52 | 8.15 | 6.77 | 7.55 | 6.58 | 6.75 | 8.04 | 6.97 | 8.13 |
| | Dibromochloromethane (ppb) | 12.8 | 11.9 | 10.2 | 12 | 11.5 | 11 | 11.6 | 10.8 | 10.8 | 13.1 | 11.4 | 13.2 |
| | Bromoform (ppb) | 14.5 | 14.3 | 11.5 | 13.7 | 12.4 | 14.2 | 13.8 | 14.2 | 13.8 | 16.7 | 14.8 | 16.6 |
| 80 | Total Regulated Trihalomethanes | 37.83 | 35.8 | 30.79 | 35.88 | 34.9 | 34.31 | 35.43 | 33.88 | 33.7 | 40.59 | 35.57 | 40.74 |

* MCL = Maximum Contaminant Level
 ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/13/2021 | 2/19/2021 | 2/19/2021 |
|-----------------------------|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 11:00 | 8:04 | 8:29 | 8:45 | 9:05 | 9:28 | 10:03 | 10:40 | 11:05 | 10:21 | 14:24 | 14:37 |
| Drinking Water | Lab ID | 2104206009 | 2104206012 | 2104206013 | 2104206014 | 2104206015 | 2104206016 | 2104206017 | 2104206018 | 2104206019 | 2104206020 | 2104503002 | 2104503003 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 3209 | 1174 | 2897 | 1685 | 2678 | 1289 | 1355 | 2955 | 3222 | 2948 | 3211 | 129 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | 0.63 | ND | ND | 0.64 | 0.62 | 0.58 | 0.54 | 0.63 | 2.67 | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | 1.13 | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 2.41 | 2.54 | 2.28 | 2.18 | 2.5 | 2.22 | 2.46 | 2.34 | 2.2 | 2.44 | 2.13 | 2.1 |
| | Bromodichloromethane (ppb) | 6.78 | 7.42 | 6.62 | 6.52 | 7.23 | 6.68 | 7.09 | 6.88 | 6.5 | 7.33 | 5.21 | 6.81 |
| | Dibromochloromethane (ppb) | 11.6 | 12.6 | 10.5 | 10 | 11 | 10.8 | 11.1 | 11.4 | 10.8 | 12.2 | 6.69 | 10.8 |
| | Bromoform (ppb) | 16.2 | 16 | 13 | 12.8 | 12.6 | 14.4 | 13.3 | 15.1 | 14.7 | 15.8 | 10.5 | 8.66 |
| 80 | Total Regulated Trihalomethanes | 36.99 | 38.56 | 32.4 | 31.5 | 33.33 | 34.1 | 33.95 | 35.72 | 34.2 | 37.77 | 24.53 | 28.37 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021

--- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 | 2/19/2021 |
|----------------|--|--------------|-------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| | Time Collected | 14:49 | 15:00 | 15:10 | 15:20 | 15:35 | 14:15 | 1:25 | 14:36 | 14:47 | 14:54 | 15:07 | 15:20 |
| Drinking Water | Lab ID | 2104503004 | 2104503005 | 2104503006 | 2104503007 | 2104503008 | 2104503009 | 2104503011 | 2104503012 | 2104503013 | 2104503014 | 2104503015 | 2104503016 |
| Regulated MCL* | Sample ID | 2046 | 2907 | 684 | 3446 | 687 | 760 | 761 | 762 | 683 | 499 | 3221 | 3216 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | 2.23 | ND | ND | ND | ND | ND | 0.82 | 0.7 | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 2.04 | 1.93 | 1.96 | 2.64 | 1.91 | 2.29 | 3.85 | 3.17 | 2.33 | 2.28 | 3.18 | 3.62 |
| | Bromodichloromethane (ppb) | 6.62 | 6.26 | 5.9 | 7.69 | 5.86 | 7.12 | 15.4 | 12 | 6.86 | 6.17 | 8.67 | 13.3 |
| | Dibromochloromethane (ppb) | 9.95 | 9.17 | 8.63 | 11.2 | 8.23 | 10 | 27.9 | 20.6 | 9.37 | 9.98 | 10.9 | 22.1 |
| | Bromoform (ppb) | 8.36 | 7.44 | 7.07 | 13 | 6.14 | 8.11 | 17.6 | 14.7 | 7.51 | 15.4 | 9.72 | 16.5 |
| 80 | Total Regulated Trihalomethanes | 26.97 | 24.8 | 23.56 | 34.53 | 22.14 | 27.52 | 64.75 | 50.47 | 26.07 | 33.83 | 32.47 | 55.52 |

* MCL = Maximum Contaminant Level
 ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 2/25/2021 | 2/25/2021 | 2/25/2021 | 2/25/2021 | 3/1/2021 | 3/1/2021 | 3/1/2021 | 3/1/2021 | 3/1/2021 | 3/4/2021 | 3/4/2021 | 3/5/2021 |
|-----------------------------|--|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 10:53 | 10:25 | 11:08 | 10:37 | 13:08 | 13:21 | 13:32 | 13:41 | 14:04 | 12:15 | 12:29 | 13:45 |
| Drinking Water | Lab ID | 2105029001 | 2105029002 | 2105029003 | 2105029004 | 2105176001 | 2105176002 | 2105176003 | 2105176004 | 2105176005 | 2105817001 | 2105817002 | 2105876001 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 1252 | 956 | 2893 | 81 | 142 | 1045 | 35 | 2893 | 956 | 2701 | 2132 | 1228 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | 0.82 | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | ND | ND | 0.55 | 1.00 | 0.63 | 0.65 | 0.89 | 1.03 | 1.65 | ND |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | 0.69 | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.62 | 2.27 | 1.93 | 2.4 | 1.76 | 3.96 | 1.87 | 1.78 | 1.99 | 1.62 | 2.24 | 1.46 |
| | Bromodichloromethane (ppb) | 3.99 | 6.38 | 5.52 | 7.88 | 4.28 | 10.2 | 4.59 | 4.39 | 5.97 | 4.22 | 3.24 | 4.11 |
| | Dibromochloromethane (ppb) | 5.69 | 9.67 | 8.36 | 12.7 | 6.2 | 13.2 | 6.94 | 6.53 | 10.8 | 7.15 | 4.05 | 6.74 |
| | Bromoform (ppb) | 6.61 | 12.2 | 9.99 | 18.7 | 6.94 | 9.91 | 7.85 | 7.22 | 14.8 | 9.78 | 5.17 | 7.96 |
| 80 | Total Regulated Trihalomethanes | 17.91 | 30.52 | 25.8 | 41.68 | 19.18 | 37.27 | 21.25 | 19.92 | 33.56 | 22.77 | 14.7 | 20.27 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 3/8/2021 | 3/8/2021 | 3/8/2021 | 3/8/2021 | 3/8/2021 | 3/10/2021 | 3/10/2021 | 3/10/2021 | 3/11/2021 | 3/11/2021 | 3/15/2021 | 3/15/2021 |
|-----------------------------|--|------------|------------|------------|------------|------------|-----------|-----------|-----------|------------|------------|------------|------------|
| | Time Collected | 10:46 | 10:59 | 11:08 | 11:22 | 11:34 | 14:22 | 14:32 | 14:46 | 14:38 | 14:48 | 14:24 | 14:36 |
| Drinking Water | Lab ID | 2105995001 | 2105995002 | 2105995003 | 2105995004 | 2105995005 | 210643001 | 210643002 | 210643003 | 2106563001 | 2106563002 | 2106679001 | 2106679002 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 683 | 2901 | 1321 | 1145 | 2866 | 762 | 3221 | 2132 | 2907 | 683 | 35 | 2893 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | 0.6 | 0.63 | 0.74 | 0.74 | 0.73 | 0.94 | 0.86 | 1.15 | 0.78 | 0.74 | 0.95 | 1.0 |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.57 | 1.6 | 1.6 | 1.58 | 1.64 | 1.69 | 1.71 | 2.07 | 1.73 | 1.86 | 2.7 | 3.43 |
| | Bromodichloromethane (ppb) | 4.41 | 4.44 | 4.52 | 4.48 | 4.89 | 5.46 | 5.53 | 2.6 | 5.17 | 5.82 | 7.87 | 8.9 |
| | Dibromochloromethane (ppb) | 7.33 | 7.5 | 7.67 | 7.39 | 9.52 | 8.92 | 10.1 | 2.97 | 8.4 | 10.3 | 11.6 | 11.8 |
| | Bromoform (ppb) | 8.92 | 9.68 | 9.75 | 8.77 | 15 | 14 | 16.5 | 4.74 | 12.5 | 15.2 | 14.1 | 9.95 |
| 80 | Total Regulated Trihalomethanes | 22.23 | 23.22 | 23.54 | 22.22 | 31.05 | 30.07 | 33.84 | 12.38 | 27.8 | 33.18 | 36.27 | 34.08 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 3/15/2021 | 3/15/2021 | 3/15/2021 | 3/17/2021 | 3/17/2021 | 3/18/2021 | 3/18/2021 | 3/22/2021 | 3/22/2021 | 3/22/2021 | 3/22/2021 | 3/22/2021 |
|----------------|--|--------------|--------------|--------------|-------------|--------------|--------------|--------------|--------------|--------------|-------------|--------------|--------------|
| | Time Collected | 14:47 | 14:59 | 15:14 | 11:11 | 11:27 | 15:59 | 16:06 | 9:51 | 10:08 | 10:21 | 10:35 | 10:48 |
| Drinking Water | Lab ID | 2106679003 | 2106679004 | 2106679005 | 2107128001 | 2107128002 | 2107129001 | 2107129002 | 2107438001 | 2107438002 | 2107438003 | 2107438004 | 2107438005 |
| Regulated MCL* | Sample ID | 142 | 3221 | 956 | 684 | 761 | 762 | 3221 | 1321 | 3267 | 2866 | 2907 | 683 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | 0.53 | 0.51 | ND | 0.75 | 0.58 | 0.51 | 0.65 | ND | ND | 0.89 | 0.54 |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 3.11 | 1.99 | 2.0 | 3.45 | 3.54 | 4.09 | 3.34 | 2.2 | 4.28 | 4.4 | 1.86 | 2.11 |
| | Bromodichloromethane (ppb) | 8.72 | 6.33 | 6.44 | 8.56 | 9.24 | 11.0 | 9.19 | 6.25 | 11.7 | 12 | 5.45 | 6.14 |
| | Dibromochloromethane (ppb) | 11.0 | 12.4 | 11.7 | 10.2 | 11.9 | 14.5 | 13.2 | 10.3 | 15.7 | 16.4 | 8.73 | 10.2 |
| | Bromoform (ppb) | 8.75 | 19.5 | 18.4 | 6.59 | 8.6 | 10.6 | 12.2 | 12.2 | 12.3 | 12.7 | 10.4 | 12.3 |
| 80 | Total Regulated Trihalomethanes | 31.58 | 40.22 | 38.54 | 28.8 | 33.28 | 40.19 | 37.93 | 30.95 | 43.98 | 45.5 | 26.44 | 30.75 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 3/24/2021 | 3/24/2021 | 3/25/2021 | 3/25/2021 | 3/29/2021 | 3/29/2021 | 3/29/2021 | 3/29/2021 | 3/29/2021 | 3/30/2021 | 3/30/2021 | 4/1/2021 |
|----------------|--|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|--------------|--------------|--------------|
| | Time Collected | 14:54 | 15:07 | 14:09 | 14:20 | 14:26 | 14:40 | 14:49 | 15:05 | 15:17 | 14:41 | 14:51 | 11:07 |
| Drinking Water | Lab ID | 2107819001 | 2107819002 | 2107818001 | 2107818002 | 210792001 | 210792002 | 210792003 | 210792004 | 210792005 | 2107993001 | 2107993002 | 2108388001 |
| Regulated MCL* | Sample ID | 142 | 3221 | 684 | 761 | 1045 | 1644 | 2950 | 762 | 3221 | 2907 | 683 | 3221 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | ND | ND | 0.64 | 0.93 | 1.58 | 1.06 | ND | 1.28 | ND | 0.65 | 0.57 | 0.53 |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.99 | 2.58 | 1.89 | 2.4 | 3.97 | 1.94 | 2.19 | 2.99 | 3.05 | 1.74 | 1.86 | 2.25 |
| | Bromodichloromethane (ppb) | 6.07 | 7.75 | 5.56 | 7.14 | 11.4 | 5.82 | 6.36 | 8.77 | 9.05 | 5.31 | 5.67 | 6.66 |
| | Dibromochloromethane (ppb) | 10.3 | 13.6 | 8.64 | 11.2 | 16.7 | 9.66 | 10.1 | 12.9 | 13.9 | 8.69 | 9.88 | 11.9 |
| | Bromoform (ppb) | 13.2 | 16.5 | 10.2 | 12.4 | 17.6 | 11.2 | 11.3 | 12.8 | 14.1 | 10.4 | 12.5 | 14.8 |
| 80 | Total Regulated Trihalomethanes | 31.56 | 40.43 | 26.29 | 33.14 | 49.67 | 28.62 | 29.95 | 37.46 | 40.1 | 26.14 | 29.91 | 35.61 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 4/1/2021 | 4/5/2021 | 4/5/2021 | 4/5/2021 | 4/5/2021 | 4/5/2021 | 4/7/2021 | 4/7/2021 | 4/8/2021 | 4/8/2021 | 4/12/2021 | 4/12/2021 |
|----------------|---------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| | Time Collected | 11:17 | 13:20 | 13:31 | 13:42 | 14:09 | 14:27 | 14:23 | 14:32 | 13:45 | 13:55 | 14:08 | 14:28 |
| Drinking Water | Lab ID | 2108388002 | 2108509001 | 2108509002 | 2108509003 | 2108509004 | 2108509005 | 2109064001 | 2109064002 | 2109063001 | 2109063002 | 2109294002 | 2109294003 |
| Regulated MCL* | Sample ID | 142 | 2132 | 684 | 761 | 1228 | 2701 | 3221 | 762 | 2907 | 683 | 2132 | 2176 |
| (ppb = ug/L) | | | | | | | | | | | | | |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | 0.96 | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | | |
| | Dibromomethane (ppb) | 0.64 | 1.11 | 0.62 | 0.51 | 0.69 | ND | 0.72 | 0.89 | ND | 0.55 | 1.35 | 0.94 |
| | Bromochloromethane (ppb) | ND | 0.54 | ND | 7.23 | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | | |
| | Chloroform (ppb) | 1.94 | 2.52 | 2.22 | 2.33 | 2.17 | 2.16 | 2.46 | 2.1 | 1.95 | 2.07 | 2.37 | 2.14 |
| | Bromodichloromethane (ppb) | 5.69 | 3.38 | 6.48 | 7.23 | 6.38 | 6.33 | 7.04 | 5.9 | 5.52 | 5.7 | 6.69 | 5.8 |
| | Dibromochloromethane (ppb) | 9.56 | 4.13 | 10.3 | 12.5 | 9.99 | 9.95 | 11.6 | 9.16 | 8.33 | 8.26 | 10.2 | 8.06 |
| | Bromoform (ppb) | 11.7 | 4.8 | 11 | 14.4 | 10.6 | 10.8 | 14.5 | 11.5 | 10.2 | 9.6 | 12.3 | 9.06 |
| 80 | Total Regulated Trihalomethanes | 28.89 | 14.83 | 30 | 36.46 | 29.14 | 29.24 | 35.6 | 28.66 | 26 | 25.63 | 31.56 | 25.06 |

* MCL = Maximum Contaminant Level
 ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.

| | Date Collected | 4/12/2021 | 4/12/2021 | 4/12/2021 | 4/12/2021 | 4/12/2021 | 4/12/2021 | 4/12/2021 | 4/14/2021 | 4/14/2021 | 4/15/2021 | 4/15/2021 |
|-----------------------------|--|-------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|
| | Time Collected | 14:37 | 14:49 | 15:00 | 15:15 | 15:29 | 15:38 | 15:58 | 15:07 | 15:18 | 9:49 | 9:55 |
| Drinking Water | Lab ID | 2109294004 | 2109294005 | 2109295001 | 2109295002 | 2109295003 | 2109295004 | 2109295005 | 2109793001 | 2109793002 | 2109786001 | 2109786002 |
| Regulated MCL* (ppb = ug/L) | Sample ID | 2175 | 2178 | 142 | 3221 | 35 | 2893 | 956 | 684 | 761 | 762 | 3221 |
| | Tetrahydrofuran (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Benzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acetone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Acrylonitrile (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 2-Butonone (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 1000 | Toluene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 100 | Styrene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Naphthalene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | 1,2- Dichloroethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | 1,2,4-Trimethylbenzene (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Vinyl chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| 5 | Methylene Chloride (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Non-Regulated Halomethanes ** | | | | | | | | | | | |
| | Dibromomethane (ppb) | 1.02 | ND | ND | ND | 0.89 | 0.64 | ND | ND | ND | 0.89 | 0.57 |
| | Bromochloromethane (ppb) | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| | Regulated Trihalomethanes ** | | | | | | | | | | | |
| | Chloroform (ppb) | 2.01 | 1.96 | 2.17 | 2.48 | 2.27 | 2.3 | 2.38 | 3.57 | 3.26 | 3.88 | 2.58 |
| | Bromodichloromethane (ppb) | 5.48 | 5.26 | 5.77 | 7.25 | 6.35 | 6.41 | 6.96 | 7.8 | 7.26 | 8.38 | 6.52 |
| | Dibromochloromethane (ppb) | 7.48 | 7.13 | 8.03 | 11.5 | 9.3 | 9.57 | 10.8 | 8.79 | 8.76 | 9.8 | 10.1 |
| | Bromoform (ppb) | 8.13 | 7.63 | 8.79 | 14.1 | 11.0 | 11.2 | 13.2 | 6.38 | 7.3 | 7.58 | 12.4 |
| 80 | Total Regulated Trihalomethanes | 23.1 | 21.98 | 24.76 | 35.33 | 28.92 | 29.48 | 33.34 | 26.54 | 26.58 | 29.64 | 31.6 |

* MCL = Maximum Contaminant Level

ND = Not Detected in Lab Sample

Values in red are above the regulated MCL

** Non-regulated halomethanes and regulated trihalomethanes are byproducts of disinfection/chlorination.

Green Sample Locations - In the Higher Pressure Plane and Lower Pressure Plane Outside the Original Isolation Zone

White Sample Locations - In the PaulAnn Area

Red Sample Locations - In the North Industrial Area

Refer to the attached sample reference map and contaminant information release

Update: Spreadsheet updated on 4/23/2021
 --- Samples dated 4-12-21, 4-14-21, and 4-15-21 included on this update.