



City of San Angelo

# Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



## LABORATORY REPORT

<b>Report To:</b> City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903	<b>Lab Number:</b> 560 <b>Collected:</b> 9:00:00 AM <b>Received:</b> 9/9/2022 <b>Reported:</b> 9/19/2022
<b>Project Name:</b> Water Production Plant <b>Contact:</b> Brandon Dickson <b>Sample ID:</b> Tap Sample	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	.10	mg/L	9/9/2022	AF	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	.95	mg/L	9/9/2022	AF	0.015	Hach 10205
Bicarbonate (HCO3)	146	mg/L	9/9/2022	AF	4	SM 2320-B
Calcium (as Ca)	86	mg/L	9/9/2022	AF	4	SM 3500-Ca-B
Chloride (Cl)	344	mg/L	9/9/2022	AF	4	SM 4500-Cl-B
Conductivity	1811	µs	9/9/2022	AF	1	SM 2510-B
Fluoride (F)	.59	mg/L	9/9/2022	AF	0.1	Hach 8029
Iron (Fe)	.01	mg/L	9/9/2022	AF	0.01	Hach 8008
Magnesium (as Mg)	64	mg/L	9/9/2022	AF	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.27	mg/L	9/9/2022	AF	0.23	Hach 10206
Ortho-phosphate (PO4)	.58	mg/L	9/9/2022	AF	0.06	Hach 8048
pH Value	7.8	units	9/9/2022	AF		SM 4500-H+
Potassium (K)	10	mg/L	9/9/2022	AF	5	Hach 8049
Sodium (Na)	204	mg/L	9/9/2022	AF	4	calc.
Sulfate (SO4)	315	mg/L	9/9/2022	AF	10	Hach 10227
Total Alkalinity (as CaCO3)	120	mg/L	9/9/2022	AF	4	SM 2320-B
Total Dissolved Solids (TDS)	1159	mg/L	9/9/2022	AF	5	calc.
Total Hardness (as CaCO3)	480	mg/L	9/9/2022	AF	4	SM 2340-C
Total Hardness (in Grains)	28.33	gr/gal	9/9/2022	AF		SM 2340-C

cc: Lab File

Elena Velez-Reyes  
Laboratory Manager