



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903			Lab Number: 564 Collected: 9:00:00 AM Received: 10/3/2022 Reported: 10/3/2022			
Project Name: Water Production Plant Contact: Brandon Dickson Sample ID: Tap Sample						
Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	10/3/2022	AF	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.86	mg/L	10/3/2022	AF	0.015	Hach 10205
Bicarbonate (HCO3)	181	mg/L	10/3/2022	AF	4	SM 2320-B
Calcium (as Ca)	75	mg/L	10/3/2022	AF	4	SM 3500-Ca-B
Chloride (Cl)	336	mg/L	10/3/2022	AF	4	SM 4500-Cl-B
Conductivity	1649	µs	10/3/2022	AF	1	SM 2510-B
Fluoride (F)	0.95	mg/L	10/3/2022	AF	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	10/3/2022	AF	0.01	Hach 8008
Magnesium (as Mg)	59	mg/L	10/3/2022	AF	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.33	mg/L	10/3/2022	AF	0.23	Hach 10206
Ortho-phosphate (PO4)	0.0	mg/L	10/3/2022	AF	0.06	Hach 8048
pH Value	7.3	units	10/3/2022	AF		SM 4500-H+
Potassium (K)	0.5	mg/L	10/3/2022	AF	5	Hach 8049
Sodium (Na)	221	mg/L	10/3/2022	AF	4	calc.
Sulfate (SO4)	274	mg/L	10/3/2022	AF	10	Hach 10227
Total Alkalinity (as CaCO3)	148	mg/L	10/3/2022	AF	4	SM 2320-B
Total Dissolved Solids (TDS)	1071	mg/L	10/3/2022	AF	5	calc.
Total Hardness (as CaCO3)	428	mg/L	10/3/2022	AF	4	SM 2340-C
Total Hardness (in Grains)	25.2	gr/gal	10/3/2022	AF		SM 2340-C

cc: Lab File

Elena Velez-Reyes
 Laboratory Manager