



City of San Angelo

# Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



## LABORATORY REPORT

<p><b>Report To:</b> City of San Angelo          Water Production Plant          327 W. Ave I          San Angelo, TX 76903</p>	<p><b>Lab Number:</b> 584  <b>Collected:</b> 10:36:00 AM  <b>Received:</b> 3/17/2023  <b>Reported:</b> 3/24/2023</p>
<p><b>Project Name:</b> Water Production Plant  <b>Contact:</b> Brandon Dickson  <b>Sample ID:</b> Tap Sample</p>	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	3/17/2023	TTS	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.78	mg/L	3/17/2023	TTS	0.015	Hach 10205
Bicarbonate (HCO3)	205	mg/L	3/17/2023	TTS	4	SM 2320-B
Calcium (as Ca)	75	mg/L	3/17/2023	TTS	4	SM 3500-Ca-B
Chloride (Cl)	320	mg/L	3/17/2023	TTS	4	SM 4500-Cl-B
Conductivity	1738	µs	3/17/2023	TTS	1	SM 2510-B
Fluoride (F)	0.75	mg/L	3/17/2023	TTS	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	3/17/2023	TTS	0.01	Hach 8008
Magnesium (as Mg)	58	mg/L	3/17/2023	TTS	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.41	mg/L	3/17/2023	TTS	0.23	Hach 10206
Ortho-phosphate (PO4)	0.01	mg/L	3/17/2023	TTS	0.06	Hach 8048
pH Value	7.9	units	3/17/2023	TTS		SM 4500-H+
Potassium (K)	12.0	mg/L	3/17/2023	TTS	5	Hach 8049
Sodium (Na)	195	mg/L	3/17/2023	TTS	4	calc.
Sulfate (SO4)	232	mg/L	3/17/2023	TTS	10	Hach 10227
Total Alkalinity (as CaCO3)	168	mg/L	3/17/2023	TTS	4	SM 2320-B
Total Dissolved Solids (TDS)	921	mg/L	3/17/2023	TTS	5	calc.
Total Hardness (as CaCO3)	424	mg/L	3/17/2023	TTS	4	SM 2340-C
Total Hardness (in Grains)	25.0	gr/gal	3/17/2023	TTS		SM 2340-C

cc: Lab File

Elena Velez-Reyes  
 Laboratory Manager