



City of San Angelo

Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



LABORATORY REPORT

Report To: City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903			Lab Number: 602 Collected: 8:40:00 AM Received: 2/21/2024 Reported: 2/21/2024			
Project Name: Water Production Plant Contact: Brandon Dickson Sample ID: Tap Sample						
Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.1	mg/L	2/21/2024	AF	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.89	mg/L	2/21/2024	AF	0.015	Hach 10205
Bicarbonate (HCO3)	161	mg/L	2/21/2024	AF	4	SM 2320-B
Calcium (as Ca)	93	mg/L	2/21/2024	AF	4	SM 3500-Ca-B
Chloride (Cl)	544	mg/L	2/21/2024	AF	4	SM 4500-Cl-B
Conductivity	2106	µs	2/21/2024	AF	1	SM 2510-B
Fluoride (F)	0.67	mg/L	2/21/2024	AF	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	2/21/2024	AF	0.01	Hach 8008
Magnesium (as Mg)	60	mg/L	2/21/2024	AF	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.51	mg/L	2/21/2024	AF	0.23	Hach 10206
Ortho-phosphate (PO4)	0.81	mg/L	2/21/2024	AF	0.06	Hach 8048
pH Value	8.03	units	2/21/2024	AF		SM 4500-H+
Potassium (K)	13	mg/L	2/21/2024	AF	5	Hach 8049
Sodium (Na)	348	mg/L	2/21/2024	AF	4	calc.
Sulfate (SO4)	334	mg/L	2/21/2024	AF	10	Hach 10227
Total Alkalinity (as CaCO3)	132	mg/L	2/21/2024	AF	4	SM 2320-B
Total Dissolved Solids (TDS)	1348	mg/L	2/21/2024	AF	5	calc.
Total Hardness (as CaCO3)	476	mg/L	2/21/2024	AF	4	SM 2340-C
Total Hardness (in Grains)	28.0	gr/gal	2/21/2024	AF		SM 2340-C

cc: Lab File

Elena Velez-Reyes
 Laboratory Manager