



City of San Angelo
Water Quality Laboratory



1324 Metcalfe St.
 San Angelo, TX 76903
 Ph: 325.481.2722 - Fax: 325.653.7278

LABORATORY REPORT

<p>Report To: City of San Angelo Water Quality Laboratory 1324 Metcalfe San Angelo, TX 76903</p>	<p>Lab Number: 628 Collected: 1:19:00 PM Received: 8/6/2024 Reported: 8/6/2024</p>
<p>Project Name: Water Production Plant Contact: Brandon Dickson Sample ID: Tap Sample</p>	

Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.10	mg/L	8/6/2024	AJC	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.66	mg/L	8/6/2024	AJC	0.015	Hach 10205
Bicarbonate (HCO3)	156	mg/L	8/6/2024	AJC	4	SM 2320-B
Calcium (as Ca)	93	mg/L	8/6/2024	AJC	4	SM 3500-Ca-B
Chloride (Cl)	412	mg/L	8/6/2024	AJC	4	SM 4500-Cl-B
Conductivity	2053	µs	8/6/2024	AJC	1	SM 2510-B
Fluoride (F)	0.78	mg/L	8/6/2024	AJC	0.1	Hach 8029
Iron (Fe)	0.01	mg/L	8/6/2024	AJC	0.01	Hach 8008
Magnesium (as Mg)	72	mg/L	8/6/2024	AJC	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.230	mg/L	8/6/2024	AJC	0.23	Hach 10206
Ortho-phosphate (PO4)	0.53	mg/L	8/6/2024	AJC	0.06	Hach 8048
pH Value	7.8	units	8/6/2024	AJC		SM 4500-H+
Potassium (K)	16.0	mg/L	8/6/2024	AJC	5	Hach 8049
Sodium (Na)	245	mg/L	8/6/2024	AJC	4	calc.
Sulfate (SO4)	356	mg/L	8/6/2024	AJC	10	Hach 10227
Total Alkalinity (as CaCO3)	128	mg/L	8/6/2024	AJC	4	SM 2320-B
Total Dissolved Solids (TDS)	1314	mg/L	8/6/2024	AJC	5	calc.
Total Hardness (as CaCO3)	528	mg/L	8/6/2024	AJC	4	SM 2340-C
Total Hardness (in Grains)	31.1	gr/gal	8/6/2024	AJC		SM 2340-C

cc: Lab File

Elena Velez-Reyes
 Laboratory Manager