



**CITY OF SAN ANGELO**  
PURCHASING DEPARTMENT  
72 West College Avenue, San Angelo, Texas 76903  
Tel: (325) 657-4219 or 657-4220

**Addendum 2**

**Date:** April 2, 2014

**RFB No:** WU-03-14/ WRF Effluent Pump

**Location:** San Angelo, Texas

**Bid Date:** April 9, 2014 / 2:00 PM, Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the specifications and contract documents:

**Submission Deadline changed to April 9, 2014 / 2:00 PM, Local Time**

**Correction to Specifications:**

**Page #11, 3.5 Pump Design Configuration (Wet pit installation)**

Replace entire first bullet with:

*"The pump shall be supplied with a mating cast iron 14 inch discharge connection and be capable to firmly connect to the existing 14-inch Flygt discharge connection, by use of the two existing 3-inch guide bars extending from the top of the station to the discharge connection."*

It is the responsibility of the bidder to ensure all addendums are considered in their pricing to prior to submitting a bid by contacting the Purchasing Department or visiting the city's website at [www.sanangelotexas.us](http://www.sanangelotexas.us). All addendums are published on the website as they are issued. Failure to do so will be at the risk of the bidders no revisions to a bid can be allowed after the bids are opened for any reason.

Sincerely,

A handwritten signature in black ink, appearing to read "Roger S. Banks".

Roger S. Banks  
Purchasing, Division Manager