

Addendum 1

Date: June 18, 2014

RFB No: WU-05-14/ Liquid Sodium Hypochlorite

Location: San Angelo, Texas

Bid Date: June 30, 2014 / 2:00 PM, Local Time

The following clarifications, changes, additions, and/or deletions are hereby made to the specifications and contract documents:

Page #17 Specificatios

Replace:

6.3 Rejection (3rd bullet point)

In the event that the replacement option is exercised, the material supplier may be required to remove the unacceptable material/items a no expense to the City of San Angelo and to deliver an equal quantity of acceptable material/equipment/services. The City reserves the option for plant personnel to feed the unsatisfactory product through the system and to be exempt from payment for the non-compliant load.

With

The City reserves the option for plant personnel to use the unsatisfactory product (levels of available Chlorine falling below 12.5%), through the water reclamation system in higher dosages to remain in compliance with TCEQ quality standards for fecal coliform. When a noncompliance of this nature occurs, the City will notify the vendor and will have a sample of the remaining load tested by our Texas state certified Lab technician to confirm concentration strength. Subsequent payment for non-conforming product will be based, at the City's discretion, on the actual % concentration of the NaOCI as determined by the City Quality Lab.

Change to Bid Due Date:

Page #3, 23, Due Date or Opening

June 25, 2014 June 30, 2014

It is the responsibility of the bidder to ensure all addendums are considered in their pricing to prior to submitting a bid by contacting the Purchasing Department or visiting the city's website at www.cosatx.us. All addendums are published on the website as they are issued. Failure to do so will be at the risk of the bidders. No revisions to a bid can be allowed after the bids are opened for any reason.

Sincerely,

Darlene Luna, CTPM Purchasing Division