



City of San Angelo

# Water Quality Laboratory

1324 Metcalfe St.

San Angelo, TX 76903

Ph: 325.481.2722 - Fax: 325.653.7278



## LABORATORY REPORT

<b>Report To:</b> City of San Angelo Water Production Plant 327 W. Ave I San Angelo, TX 76903			<b>Lab Number:</b> 44 <b>Collected:</b> 9:30:00 AM <b>Received:</b> 7/15/2014 <b>Reported:</b> 7/17/2014			
<b>Project Name:</b> Water Production Plant <b>Contact:</b> Charles McGuire <b>Sample ID:</b> Tap Sample						
Analyte	Results	Units	Test Date	By	DL	Method
Aluminum (Al)	0.1	mg/L	7/15/2014	CGM	0.1	Hach 8012
Ammonia nitrogen (NH3-N)	0.95	mg/L	7/15/2014	CGM	0.015	Hach 10205
Bicarbonate (HCO3)	142	mg/L	7/15/2014	CGM	4	SM 2320-B
Calcium (as Ca)	75	mg/L	7/15/2014	CGM	4	SM 3500-Ca-B
Chloride (Cl)	212	mg/L	7/15/2014	CGM	4	SM 4500-Cl-B
Conductivity	1283	µs	7/15/2014	CGM	1	SM 2510-B
Fluoride (F)	0.38	mg/L	7/15/2014	CGM	0.1	Hach 8029
Iron (Fe)	0.02	mg/L	7/15/2014	CGM	0.01	Hach 8008
Magnesium (as Mg)	40	mg/L	7/15/2014	CGM	4	SM 3500-Mg-B
Nitrate nitrogen (NO3-N)	0.29	mg/L	7/15/2014	CGM	0.23	Hach 10206
Ortho-phosphate (PO4)	0.06	mg/L	7/15/2014	CGM	0.06	Hach 8048
pH Value	7.8	units	7/15/2014	CGM		SM 4500-H+
Potassium (K)	12.0	mg/L	7/15/2014	CGM	5	Hach 8049
Sodium (Na)	141	mg/L	7/15/2014	CGM	4	calc.
Sulfate (SO4)	247	mg/L	7/15/2014	CGM	10	Hach 10227
Total Alkalinity (as CaCO3)	116	mg/L	7/15/2014	CGM	4	SM 2320-B
Total Dissolved Solids (TDS)	872	mg/L	7/15/2014	CGM	5	calc.
Total Hardness (as CaCO3)	352	mg/L	7/15/2014	CGM	4	SM 2340-C
Total Hardness (in Grains)	20.7	gr/gal	7/15/2014	CGM		SM 2340-C

cc: Lab File

Tymn Combest  
Water Quality Superintendent